

FIRE PROTECTION RISER DETAIL



COVER DETAIL



DITCH & STREAM CROSSING



ASBESTOS CEMENT (AC) WATER MAIN



ELBOWS					
PIPE DIA. INCHES		BEARING AREA SQUARE FEET			
		90°	45°	22 1/2°	11 1/4°
4		2.1	1.1	0.6	0.3
6		4.1	2.2	1.1	0.6
8		6.8	3.7	1.9	0.9
10		10.1	5.5	2.8	1.4
12		14.1	7.6	3.9	2.0
16		24.2	13.0	6.7	3.3
18		30.0	16.3	8.3	4.2
20		36.8	19.9	10.1	5.1

TEES, CROSSES & HYDRANTS		
PIPE DIA. INCHES		BEARING AREA SQUARE FEET
4		1.5
6		2.9
8		4.8
10		7.1
12		10.0
16		17.1
18		21.0
20		26.0

NOTES:
1. CONCRETE FOR ALL THRUST BLOCKS SHALL BE 3000 PSI, 28 DAY STRENGTH MIN.
2. ALL THRUST BLOCKS SHALL BE POURED AGAINST UNDISTURBED EARTH
3. BOLTS, FITTINGS & JOINTS SHALL BE KEPT CLEAR OF CONCRETE
4. A BEARING CAPACITY OF 2000# PER FOOT WAS USED IN DETERMINING THE MINIMUM "BEARING AREAS" IN THE ABOVE TABLE
5. THE CROSS SECTION OF THE THRUST BLOCKS SHALL BE SQUARE
6. IN ADDITION TO THRUST BLOCKS, ALL PIPE JOINTS SHALL BE RESTRAINED WITH LOCKING GASKETS PER DIPRA'S STANDARDS.

SOIL CHARACTERISTICS	FACTOR
(A) LOOSE COARSE OR MEDIUM SAND; COMPACT FINE SAND; COMPACT SAND-CLAY SOILS; STIFF CLAY	0.33
(B) FIRM FINE SAND; COMPACT INORGANIC SILT; FIRM SAND-CLAY SOILS; MEDIUM CLAY	0.50
(C) LOOSE FINE SAND; FIRM INORGANIC SILT	0.67
(D) LOOSE SAND-CLAY SOILS; LOOSE INORGANIC SILT SOFT CLAY	1.00

"BEARING AREA" x FACTOR = ACTUAL BEARING AREA
2.1 x .5 = 1.05 SQ. FT.
BASED UPON 150# TEST PRESSURE

THRUST BLOCK



TYPICAL L TRENCH DETAIL HOUSE LEADS



SEWER OR CULVERT CROSSING



WATER MAIN CONNECTION

PRE-CAST CONCRETE MANHOLE
1. SECTIONS SHALL MEET ASTM C478.
2. ALL JOINTS MADE WATERTIGHT WITH RUBBER GASKET JOINTS
3. CONE TO BE OFFSET STEP ECCENTRIC TYPE
4. ALL MANHOLE COMPONENT PARTS SHALL HAVE THE NAME OF THE MANUFACTURER STENCILED ON THE INSIDE. THE LETTERING SHALL BE A MINIMUM OF 4" HIGH.



NOTE:
GATE VALVE IS NOT CENTERED IN GATEWELL



TAPPING SLEEVE & VALVE & WELL



BLUE, 12 GAUGE SINGLE STRAND TRACER WIRE ATTACHED TO WATER MAIN PIPE MUST BE WRAPPED WITH POLLY WRAP AND SECURELY TAPED AT ENDS.

NOTES:
1. MINIMUM TRENCH WIDTH (SEE TABLE).
2. RECESS TRENCH TO RELIEVE THE BELL OF ALL LOAD. PIPE HAUNCHES SHALL BE COMPACTED.
3. 2NS BACKFILL TO DEPTH OF ONE FOOT ABOVE PIPE. TAMPED LAYERS NOT TO EXCEED 6" IN DEPTH. PLATE COMPACT ABOVE PIPE (ON 1st LIFT)
4. ALL PIPE TO BE PLACED AND JOINTED IN A DRY TRENCH AND LAID ACCURATELY TO LINE AND GRADE WITH BELLS UPHILL.
5. ALL CONCRETE ENCASEMENT AND CRADLING TO BE CLASS "A" CONCRETE.

PIPE	D	W	B
PVC	0"-12"	12" MIN. 18" MAX.	4"
A-C,V.C.P.	0"-12"	6" MIN. 12" MAX.	4"
DIP	0"-24"	6" MIN. 12" MAX.	4"
A-C,CONC.	0"-24"	6" MIN. 12" MAX.	4"
CONC. DIP	24" +	6" MIN. 12" MAX.	4"

BEDDING



NOTES:
1. SADDLE MAY BE REQUIRED ON MAIN BASED ON LEAD SIZE, MAIN SIZE, AND MAIN PRESSURE
2. ALL WATER MAIN TAPS AND COMPONENT PARTS SHALL BE APPROVED BY THE PITTSFIELD TOWNSHIP UTILITIES DEPARTMENT PRIOR TO INSTALLATION.
3. INSTALLATION SHALL BE INSPECTED AND APPROVED BY THE PITTSFIELD TOWNSHIP UTILITIES DEPARTMENT.

IRRIGATION METER PIT DETAIL



RED "REFLECTIVE" LETTERS WITH WHITE "REFLECTIVE" BACKGROUND. LETTERS WILL BE A MINIMUM OF 8" TALL BY 4" WIDE WITH 2" GIRTH, WITH AN 8" TALL 4" WIDE RED ARROW UNDER LETTERS POINTING DIRECTLY AT THE CONNECTION. TALLER BUILDINGS MAY REQUIRE LARGER LETTERING. SIGN SIZE AND LOCATION DETERMINED BY FIRE MARSHALL

FIRE DEPARTMENT CONNECTION LABEL DETAIL

PRE-CAST CONCRETE MANHOLE
1. SECTIONS SHALL MEET ASTM C478.
2. ALL JOINTS MADE WATERTIGHT WITH RUBBER GASKET JOINTS
3. CONE TO BE OFFSET STEP ECCENTRIC TYPE
4. ALL MANHOLE COMPONENT PARTS SHALL HAVE THE NAME OF THE MANUFACTURER STENCILED ON THE INSIDE. THE LETTERING SHALL BE A MINIMUM OF 4" HIGH.
5. PROVIDE INTEGRAL BASE.
6. KOR-N-SEAL BOOTS OR APPROVED EQUAL TO BE INSTALLED AT PIPE PENETRATIONS.
7. WHERE GATE WELLS ARE CONSTRUCTED OVER EXISTING WATERMAIN, POURED IN PLACE OR PRECAST COOKIE AND DOGHOUSE STRUCTURES MY BE USED IN PLACE OF INTEGRAL BASE.



NOTE:
GATE VALVE IS NOT CENTERED IN GATEWELL

STRAIGHT THRU		TEE
VALVE SIZE	"D"	"D"
8"	5'-0"	6'-0"
12"	5'-0"	6'-0"
16"	6'-0"	6'-0"



STANDARD GATE VALVE & WELL



NOTES:
-PROVIDE ONE 4-INCH STORZ CONNECTION ON EACH HYDRANT ON THE LEFT NOZZLE WHEN FACING THE HYDRANT
-HYDRANTS SHALL FACE THE PARKING LOT OR DRIVEWAY OR AS DIRECTED BY THE FIRE MARSHALL

STANDARD FIRE HYDRANT



METER ROOM DETAIL

Pittsfield Charter Township
6201 W. Michigan Ave.
Ann Arbor, MI 48108-9721
48108-9721
Tel. 734.822.3101
www.pittsfield-mi.gov

Revision	By	Appd.	YY.MM.DD
METER UPDATE	BWA	EJH	22.06.30
CROSSING UPDATE	FDA	DRW	14.05.09
UPDATES	MRH	DRW	14.01.24
FDC UPDATE	BWA	DRW	11.09.13
TWP REV	BWA	DRW	11.04.27
HYDRANT, MANHOLE UPDATE	BWA	DRW	10.10.25
UPDATES	TTN	DRW	10.01.20

Issued	By	Appd.	YY.MM.DD
File Name: W-01	BWA	DRW	07.10.01
	Dwn.	Chkd.	Dsgn. YY.MM.DD

Permit-Seal

Client/Project
PITTSFIELD TOWNSHIP

Pittsfield Township, Michigan

Title
WATER MAIN DETAILS

Project No.
2075001300

Scale
NOT TO SCALE

Revision